

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 9,)**

Water Level of the accumulated water (at 0:00 on October 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 908 mm (3 mm decrease since 0:00 on October 8)	T.P.+ 741 mm (32 mm decrease since 0:00 on October 8)	T.P.+ 898 mm (11 mm decrease since 0:00 on October 8)
	Water level of Reactor Building	T.P.+ 947 mm (17 mm increase since 0:00 on October 8)	T.P.+ 951 mm (7 mm increase since 0:00 on October 8)	T.P.+ 772 mm (42 mm decrease since 0:00 on October 8)	T.P.+ 808 mm (1 mm decrease since 0:00 on October 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -353 mm (40 mm decrease since 0:00 on October 8) T.P.+ 908 mm ( 1 mm increase since 0:00 on October 8) T.P.+ 2,800 mm (26 mm increase since 0:00 on October 8)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.