

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 10,)**

Water Level of the accumulated water (at 0:00 on October 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 908 mm (No change since 0:00 on October 9)	T.P.+ 760 mm (19 mm increase since 0:00 on October 9)	T.P.+ 899 mm (1 mm increase since 0:00 on October 9)
	Water level of Reactor Building	T.P.+ 942 mm (5 mm decrease since 0:00 on October 9)	T.P.+ 970 mm (19 mm increase since 0:00 on October 9)	T.P.+ 789 mm (17 mm increase since 0:00 on October 9)	T.P.+ 807 mm (1 mm decrease since 0:00 on October 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -507 mm (154 mm decrease since 0:00 on October 9) T.P.+ 909 mm (1 mm increase since 0:00 on October 9) T.P.+ 2,825 mm (25 mm increase since 0:00 on October 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.