

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 12,)**

Water Level of the accumulated water (at 0:00 on October 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 913 mm (5 mm increase since 0:00 on October 11)	T.P.+ 747 mm (18 mm decrease since 0:00 on October 11)	T.P.+ 902 mm (3 mm decrease since 0:00 on October 11)
	Water level of Reactor Building	T.P.+ 951 mm (3 mm increase since 0:00 on October 11)	T.P.+ 952 mm (9 mm decrease since 0:00 on October 11)	T.P.+ 791 mm (5 mm decrease since 0:00 on October 11)	T.P.+ 806 mm (1 mm decrease since 0:00 on October 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -389 mm (113 mm increase since 0:00 on October 11) T.P.+ 920 mm (10 mm increase since 0:00 on October 11) T.P.+ 2,888 mm (34 mm increase since 0:00 on October 11)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.