

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 19,)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 0:00 on October 19)	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 917 mm (No change since 0:00 on October 18)	T.P.+ 786 mm (19 mm decrease since 0:00 on October 18)	T.P.+ 911 mm (10 mm decrease since 0:00 on October 18)
	Water level of Reactor Building	T.P.+ 911 mm (3 mm increase since 0:00 on October 18)	T.P.+ 931 mm (37 mm decrease since 0:00 on October 18)	T.P.+ 833 mm (9 mm decrease since 0:00 on October 18)	T.P.+ 804 mm (1 mm decrease since 0:00 on October 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -625 mm (112 mm increase since 0:00 on October 18) T.P.+ 935 mm (1 mm decrease since 0:00 on October 18) T.P.+ 2,926 mm (32 mm increase since 0:00 on October 18)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.