

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 24,)**

Water Level of the accumulated water (at 0:00 on October 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 997 mm (142 mm increase since 0:00 on October 23)	T.P.+ 975 mm (138 mm increase since 0:00 on October 23)	T.P.+ 886 mm (42 mm increase since 0:00 on October 23)
	Water level of Reactor Building	T.P.+ 1,216 mm (156 mm increase since 0:00 on October 23)	T.P.+ 973 mm (14 mm increase since 0:00 on October 23)	T.P.+ 1,012 mm (109 mm increase since 0:00 on October 23)	T.P.+ 787 mm (19 mm increase since 0:00 on October 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 46 mm (197 mm increase since 0:00 on October 23) T.P.+ 1,019 mm (56 mm increase since 0:00 on October 23) T.P.+ 2,915 mm (46 mm increase since 0:00 on October 23)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.