

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 31,)**

| Water Level of the accumulated water<br>(at 0:00 on October 31) |  | Unit 1  | Unit 2   | Unit 3  | Unit 4   |
|---|--|---|--|---|--|
|   | Water level of Turbine Building  | -<br>Removal completed on March, 2017   | T.P.+ 895 mm<br>(2 mm decrease since 0:00 on October 30)   | T.P.+ 769 mm<br>(9 mm increase since 0:00 on October 30)  | T.P.+ 976 mm<br>(1 mm increase since 0:00 on October 30) |
|   | Water level of Reactor Building  | T.P.+ 806 mm<br>(3 mm decrease since 0:00 on October 30)  | T.P.+ 959 mm<br>(28 mm increase since 0:00 on October 30)  | T.P.+ 808 mm<br>(18 mm decrease since 0:00 on October 30) | T.P.+ 813 mm<br>(5 mm increase since 0:00 on October 30) |
|   | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br><br>High Temperature Incinerator Building<br><br>On-site Bunker Building | T.P.+ 2,141 mm (219 mm increase since 0:00 on October 30)<br><br>T.P.+ 1,041 mm ( 25 mm increase since 0:00 on October 30)<br><br>T.P.+ 2,850 mm (28 mm increase since 0:00 on October 30) |   |  |
| Notes   |  |   |  |   |  |

※ For quick publication of the data of water level, values are provided as reference values.