

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on November 1,)**

Water Level of the accumulated water (at 0:00 on November 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 898 mm (3 mm increase since 0:00 on October 31)	T.P.+ 808 mm (39 mm increase since 0:00 on October 31)	T.P.+ 964 mm (12 mm decrease since 0:00 on October 31)
	Water level of Reactor Building	T.P.+ 808 mm (2 mm increase since 0:00 on October 31)	T.P.+ 954 mm (5 mm decrease since 0:00 on October 31)	T.P.+ 847 mm (39 mm increase since 0:00 on October 31)	T.P.+ 818 mm (5 mm increase since 0:00 on October 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,337 mm (196 mm increase since 0:00 on October 31) T.P.+ 1,041 mm (No change since 0:00 on October 31) T.P.+ 2,879 mm (29 mm increase since 0:00 on October 31)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.