

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on November 2,)**

Water Level of the accumulated water (at 0:00 on November 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 915 mm (17 mm increase since 0:00 on November 1)	T.P.+ 814 mm (6 mm increase since 0:00 on November 1)	T.P.+ 952 mm (12 mm decrease since 0:00 on November 1)
	Water level of Reactor Building	T.P.+ 801 mm (7 mm decrease since 0:00 on November 1)	T.P.+ 959 mm (5 mm increase since 0:00 on November 1)	T.P.+ 866 mm (19 mm increase since 0:00 on November 1)	T.P.+ 820 mm (2 mm increase since 0:00 on November 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,434 mm (97 mm increase since 0:00 on November 1) T.P.+ 1,037 mm (4 mm decrease since 0:00 on November 1) T.P.+ 2,906 mm (27 mm increase since 0:00 on November 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.