

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on November 3,)**

Water Level of the accumulated water (at 0:00 on November 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 925 mm (10 mm increase since 0:00 on November 2)	T.P.+ 798 mm (16 mm decrease since 0:00 on November 2)	T.P.+ 935 mm (17 mm decrease since 0:00 on November 2)
	Water level of Reactor Building	T.P.+ 801 mm (No change since 0:00 on November 2)	T.P.+ 965 mm (6 mm increase since 0:00 on November 2)	T.P.+ 850 mm (16 mm decrease since 0:00 on November 2)	T.P.+ 819 mm (1 mm decrease since 0:00 on November 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,487 mm (53 mm increase since 0:00 on November 2) T.P.+ 1,085 mm (48 mm increase since 0:00 on November 2) T.P.+ 2,932 mm (26 mm increase since 0:00 on November 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.