

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on November 5,)**

Water Level of the accumulated water (at 0:00 on November 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 923 mm (No change since 0:00 on November 4)	T.P.+ 800 mm (27 mm increase since 0:00 on November 4)	T.P.+ 921 mm (9 mm increase since 0:00 on November 4)
	Water level of Reactor Building	T.P.+ 806 mm (12 mm increase since 0:00 on November 4)	T.P.+ 956 mm (3 mm decrease since 0:00 on November 4)	T.P.+ 842 mm (27 mm increase since 0:00 on November 4)	T.P.+ 812 mm (1 mm increase since 0:00 on November 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,419 mm (149 mm decrease since 0:00 on November 4) T.P.+ 1,090 mm (4 mm increase since 0:00 on November 4) T.P.+ 2,714 mm (18 mm increase since 0:00 on November 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.