

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on November 10,)**

Water Level of the accumulated water (at 0:00 on November 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 905 mm (3 mm increase since 0:00 on November 9)	T.P.+ 798 mm (24 mm increase since 0:00 on November 9)	T.P.+ 918 mm (6 mm increase since 0:00 on November 9)
	Water level of Reactor Building	T.P.+ 799 mm (17 mm increase since 0:00 on November 9)	T.P.+ 961 mm (5 mm decrease since 0:00 on November 9)	T.P.+ 817 mm (16 mm decrease since 0:00 on November 9)	T.P.+ 800 mm (No change since 0:00 on November 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,903 mm (150 mm decrease since 0:00 on November 9) T.P.+ 1,105 mm (4 mm increase since 0:00 on November 9) T.P.+ 2,696 mm (No change since 0:00 on November 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.