

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 2,)**

Water Level of the accumulated water (at 0:00 on December 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 730 mm (4 mm increase since 0:00 on December 1)	T.P.+ 601 mm (16 mm increase since 0:00 on December 1)	T.P.+ 724 mm (7 mm increase since 0:00 on December 1)
	Water level of Reactor Building	T.P.+ 700 mm (1 mm decrease since 0:00 on December 1)	T.P.+ 737 mm (9 mm decrease since 0:00 on December 1)	T.P.+ 635 mm (14 mm increase since 0:00 on December 1)	T.P.+ 700 mm (6 mm decrease since 0:00 on December 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,002 mm (180 mm decrease since 0:00 on December 1) T.P.+ 1,205 mm (3 mm increase since 0:00 on December 1) T.P.+ 2,693 mm (1 mm decrease since 0:00 on December 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.