

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 3,)**

Water Level of the accumulated water (at 0:00 on December 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 727 mm (3 mm decrease since 0:00 on December 2)	T.P.+ 569 mm (32 mm decrease since 0:00 on December 2)	T.P.+ 720 mm (4 mm decrease since 0:00 on December 2)
	Water level of Reactor Building	T.P.+ 686 mm (14 mm decrease since 0:00 on December 2)	T.P.+ 762 mm (25 mm increase since 0:00 on December 2)	T.P.+ 605 mm (30 mm decrease since 0:00 on December 2)	T.P.+ 695 mm (5 mm decrease since 0:00 on December 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,968 mm (34 mm decrease since 0:00 on December 2) T.P.+ 1,210 mm (5 mm increase since 0:00 on December 2) T.P.+ 2,693 mm (No change since 0:00 on December 2)		
Notes					

For quick publication of the data of water level, values are provided as reference values.