

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 4,)**

Water Level of the accumulated water (at 0:00 on December 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 726 mm (1 mm decrease since 0:00 on December 3)	T.P.+ 585 mm (16 mm increase since 0:00 on December 3)	T.P.+ 728 mm (8 mm increase since 0:00 on December 3)
	Water level of Reactor Building	T.P.+ 691 mm (5 mm increase since 0:00 on December 3)	T.P.+ 762 mm (No change since 0:00 on December 3)	T.P.+ 619 mm (14 mm increase since 0:00 on December 3)	T.P.+ 692 mm (3 mm decrease since 0:00 on December 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,798 mm (170 mm decrease since 0:00 on December 3) T.P.+ 1,213 mm (3 mm increase since 0:00 on December 3) T.P.+ 2,696 mm (3 mm increase since 0:00 on December 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.