

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 7,)**

Water Level of the accumulated water (at 0:00 on December 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 698 mm (16 mm increase since 0:00 on December 6)	T.P.+ 599 mm (7 mm decrease since 0:00 on December 6)	T.P.+ 691 mm (33 mm decrease since 0:00 on December 6)
	Water level of Reactor Building	T.P.+ 700 mm (10 mm increase since 0:00 on December 6)	T.P.+ 767 mm (12 mm increase since 0:00 on December 6)	T.P.+ 651 mm (5 mm increase since 0:00 on December 6)	T.P.+ 677 mm (5 mm decrease since 0:00 on December 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,626 mm (36 mm decrease since 0:00 on December 6) T.P.+ 1,225 mm (4 mm increase since 0:00 on December 6) T.P.+ 2,737 mm (14 mm increase since 0:00 on December 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.