

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 10,)**

Water Level of the accumulated water (at 0:00 on December 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 690 mm (24 mm increase since 0:00 on December 9)	T.P.+ 564 mm (14 mm increase since 0:00 on December 9)	T.P.+ 666 mm (5 mm increase since 0:00 on December 9)
	Water level of Reactor Building	T.P.+ 691 mm (16 mm decrease since 0:00 on December 9)	T.P.+ 762 mm (16 mm increase since 0:00 on December 9)	T.P.+ 605 mm (14 mm increase since 0:00 on December 9)	T.P.+ 659 mm (5 mm decrease since 0:00 on December 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,419 mm (307 mm decrease since 0:00 on December 9) T.P.+ 1,239 mm (5 mm increase since 0:00 on December 9) T.P.+ 2,776 mm (13 mm increase since 0:00 on December 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.