

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 11,)**

Water Level of the accumulated water (at 0:00 on December 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 703 mm (13 mm increase since 0:00 on December 10)	T.P.+ 575 mm (11 mm increase since 0:00 on December 10)	T.P.+ 671 mm (5 mm increase since 0:00 on December 10)
	Water level of Reactor Building	T.P.+ 704 mm (13 mm increase since 0:00 on December 10)	T.P.+ 769 mm (7 mm increase since 0:00 on December 10)	T.P.+ 619 mm (14 mm increase since 0:00 on December 10)	T.P.+ 656 mm (3 mm decrease since 0:00 on December 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,220 mm (199 mm decrease since 0:00 on December 10) T.P.+ 1,245 mm ( 6 mm increase since 0:00 on December 10) T.P.+ 2,789 mm (13 mm increase since 0:00 on December 10)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.