

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on December 21,)**

Water Level of the accumulated water (at 0:00 on December 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 708 mm (2 mm decrease since 0:00 on December 20)	T.P.+ 511 mm (19 mm decrease since 0:00 on December 20)	T.P.+ 601 mm (9 mm increase since 0:00 on December 20)
	Water level of Reactor Building	T.P.+ 698 mm (17 mm increase since 0:00 on December 20)	T.P.+ 765 mm (No change since 0:00 on December 20)	T.P.+ 567 mm (33 mm decrease since 0:00 on December 20)	T.P.+ 606 mm (3 mm decrease since 0:00 on December 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 258 mm (130 mm decrease since 0:00 on December 20) T.P.+ 1,231 mm (100 mm decrease since 0:00 on December 20) T.P.+ 2,944 mm (17 mm increase since 0:00 on December 20)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.