

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 1,)**

Water Level of the accumulated water (at 0:00 on January 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 406 mm (5 mm increase since 0:00 on December 31)	T.P.+ 385 mm (34 mm increase since 0:00 on December 31)	T.P.+ 438 mm (10 mm increase since 0:00 on December 31)
	Water level of Reactor Building	T.P.+ 415 mm (9 mm decrease since 0:00 on December 31)	T.P.+ 436 mm (18 mm decrease since 0:00 on December 31)	T.P.+ 453 mm (19 mm increase since 0:00 on December 31)	T.P.+ 436 mm (8 mm increase since 0:00 on December 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,148 mm (60 mm increase since 0:00 on December 31) T.P.+ 944 mm ( No change since 0:00 on December 31) T.P.+ 2,819 mm (11 mm increase since 0:00 on December 31)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.