

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 4,)**

Water Level of the accumulated water (at 0:00 on January 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 403 mm (2 mm increase since 0:00 on January 3)	T.P.+ 379 mm (2 mm decrease since 0:00 on January 3)	T.P.+ 428 mm (29 mm decrease since 0:00 on January 3)
	Water level of Reactor Building	T.P.+ 416 mm (6 mm decrease since 0:00 on January 3)	T.P.+ 445 mm (21 mm increase since 0:00 on January 3)	T.P.+ 448 mm (No change since 0:00 on January 3)	T.P.+ 440 mm (2 mm decrease since 0:00 on January 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,426 mm (124 mm increase since 0:00 on January 3) T.P.+ 944 mm (No change since 0:00 on January 3) T.P.+ 2,859 mm (14 mm increase since 0:00 on January 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.