

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 7,)**

Water Level of the accumulated water (at 0:00 on January 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 398 mm (No change since 0:00 on January 6)	T.P.+ 370 mm (3 mm decrease since 0:00 on January 6)	T.P.+ 454 mm (10 mm increase since 0:00 on January 6)
	Water level of Reactor Building	T.P.+ 411 mm (13 mm decrease since 0:00 on January 6)	T.P.+ 455 mm (No change since 0:00 on January 6)	T.P.+ 444 mm (No change since 0:00 on January 6)	T.P.+ 431 mm (4 mm decrease since 0:00 on January 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 1,778 mm (122 mm increase since 0:00 on January 6)  T.P.+ 944 mm ( 1 mm increase since 0:00 on January 6)  T.P.+ 2,902 mm (14 mm increase since 0:00 on January 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.