

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 10,)**

Water Level of the accumulated water (at 0:00 on January 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 397 mm (6 mm decrease since 0:00 on January 9)	T.P.+ 366 mm (No change since 0:00 on January 9)	T.P.+ 442 mm (8 mm increase since 0:00 on January 9)
	Water level of Reactor Building	T.P.+ 419 mm (2 mm decrease since 0:00 on January 9)	T.P.+ 461 mm (30 mm increase since 0:00 on January 9)	T.P.+ 444 mm (No change since 0:00 on January 9)	T.P.+ 425 mm (2 mm decrease since 0:00 on January 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,208 mm (156 mm increase since 0:00 on January 9) T.P.+ 942 mm (1 mm decrease since 0:00 on January 9) T.P.+ 2,942 mm (13 mm increase since 0:00 on January 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.