

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 12,)**

Water Level of the accumulated water (at 0:00 on January 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 405 mm (4 mm increase since 0:00 on January 11)	T.P.+ 363 mm (4 mm increase since 0:00 on January 11)	T.P.+ 457 mm (6 mm increase since 0:00 on January 11)
	Water level of Reactor Building	T.P.+ 412 mm (15 mm decrease since 0:00 on January 11)	T.P.+ 427 mm (37 mm decrease since 0:00 on January 11)	T.P.+ 465 mm (21 mm increase since 0:00 on January 11)	T.P.+ 420 mm (2 mm decrease since 0:00 on January 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,459 mm (118 mm increase since 0:00 on January 11) T.P.+ 942 mm (1 mm decrease since 0:00 on January 11) T.P.+ 2,967 mm (13 mm increase since 0:00 on January 11)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.