

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 15,)**

Water Level of the accumulated water (at 0:00 on January 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 401 mm (No change since 0:00 on January 14)	T.P.+ 384 mm (3 mm decrease since 0:00 on January 14)	T.P.+ 431 mm (7 mm increase since 0:00 on January 14)
	Water level of Reactor Building	T.P.+ 412 mm (2 mm increase since 0:00 on January 14)	T.P.+ 454 mm (7 mm decrease since 0:00 on January 14)	T.P.+ 469 mm (No change since 0:00 on January 14)	T.P.+ 403 mm (3 mm decrease since 0:00 on January 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,699 mm (70 mm increase since 0:00 on January 14)  T.P.+ 944 mm ( 1 mm increase since 0:00 on January 14)  T.P.+ 3,016 mm (17 mm increase since 0:00 on January 14)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.