

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 20,)**

Water Level of the accumulated water (at 0:00 on January 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 401 mm (2 mm increase since 0:00 on January 19)	T.P.+ 363 mm (1 mm increase since 0:00 on January 19)	T.P.+ 430 mm (6 mm increase since 0:00 on January 19)
	Water level of Reactor Building	T.P.+ 431 mm (25 mm increase since 0:00 on January 19)	T.P.+ 453 mm (3 mm decrease since 0:00 on January 19)	T.P.+ 462 mm (2 mm decrease since 0:00 on January 19)	T.P.+ 393 mm (3 mm decrease since 0:00 on January 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,597 mm (96 mm decrease since 0:00 on January 19) T.P.+ 982 mm (2 mm increase since 0:00 on January 19) T.P.+ 3,095 mm (15 mm increase since 0:00 on January 19)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.