

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on January 26,)**

| Water Level of the accumulated water (at 0:00 on January 26) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|---|--|---|--|---|--|
| | Water level of Turbine Building | - Removal completed on March, 2017 | T.P.+ 392 mm (14 mm decrease since 0:00 on January 25) | T.P.+ 366 mm (7 mm decrease since 0:00 on January 25) | T.P.+ 429 mm (7 mm increase since 0:00 on January 25) |
| | Water level of Reactor Building | T.P.+ 417 mm (65 mm decrease since 0:00 on January 25) | T.P.+ 454 mm (14 mm decrease since 0:00 on January 25) | T.P.+ 467 mm (11 mm decrease since 0:00 on January 25) | T.P.+ 382 mm (1 mm decrease since 0:00 on January 25) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ 2,436 mm (124 mm increase since 0:00 on January 25) T.P.+ 916 mm (69 mm decrease since 0:00 on January 25) T.P.+ 2,876 mm (13 mm increase since 0:00 on January 25) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.