

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 2,)**

Water Level of the accumulated water (at 0:00 on February 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 400 mm (5 mm increase since 0:00 on February 1)	T.P.+ 338 mm (13 mm decrease since 0:00 on February 1)	T.P.+ 427 mm (6 mm increase since 0:00 on February 1)
	Water level of Reactor Building	T.P.+ 437 mm (No change since 0:00 on February 1)	T.P.+ 433 mm (28 mm decrease since 0:00 on February 1)	T.P.+ 452 mm (12 mm decrease since 0:00 on February 1)	T.P.+ 372 mm (1 mm decrease since 0:00 on February 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,542 mm (2 mm increase since 0:00 on February 1) T.P.+ -51 mm (77 mm increase since 0:00 on February 1) T.P.+ 2,690 mm (No change since 0:00 on February 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.