

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 3,)**

Water Level of the accumulated water (at 0:00 on February 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 402 mm (2 mm increase since 0:00 on February 2)	T.P.+ 363 mm (25 mm increase since 0:00 on February 2)	T.P.+ 430 mm (3 mm increase since 0:00 on February 2)
	Water level of Reactor Building	T.P.+ 430 mm (7 mm decrease since 0:00 on February 2)	T.P.+ 461 mm (28 mm increase since 0:00 on February 2)	T.P.+ 481 mm (29 mm increase since 0:00 on February 2)	T.P.+ 371 mm (1 mm decrease since 0:00 on February 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,544 mm (2 mm increase since 0:00 on February 2) T.P.+ 134 mm (185 mm increase since 0:00 on February 2) T.P.+ 2,690 mm (No change since 0:00 on February 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.