

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 4,)**

Water Level of the accumulated water (at 0:00 on February 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 409 mm (7 mm increase since 0:00 on February 3)	T.P.+ 376 mm (13 mm increase since 0:00 on February 3)	T.P.+ 436 mm (6 mm increase since 0:00 on February 3)
	Water level of Reactor Building	T.P.+ 409 mm (21 mm decrease since 0:00 on February 3)	T.P.+ 451 mm (10 mm decrease since 0:00 on February 3)	T.P.+ 499 mm (18 mm increase since 0:00 on February 3)	T.P.+ 370 mm (1 mm decrease since 0:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,548 mm (4 mm increase since 0:00 on February 3) T.P.+ 322 mm (188 mm increase since 0:00 on February 3) T.P.+ 2,690 mm (No change since 0:00 on February 3)		
Notes					

For quick publication of the data of water level, values are provided as reference values.