

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 5,)**

Water Level of the accumulated water (at 0:00 on February 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 412 mm (3 mm increase since 0:00 on February 4)	T.P.+ 387 mm (11 mm increase since 0:00 on February 4)	T.P.+ 440 mm (4 mm increase since 0:00 on February 4)
	Water level of Reactor Building	T.P.+ 407 mm (2 mm decrease since 0:00 on February 4)	T.P.+ 440 mm (11 mm decrease since 0:00 on February 4)	T.P.+ 514 mm (15 mm increase since 0:00 on February 4)	T.P.+ 370 mm (No change since 0:00 on February 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,548 mm (No change since 0:00 on February 4) T.P.+ 501 mm (179 mm increase since 0:00 on February 4) T.P.+ 2,690 mm (No change since 0:00 on February 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.