

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 7,)**

Water Level of the accumulated water (at 0:00 on February 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 414 mm (32 mm increase since 0:00 on February 6)	T.P.+ 372 mm (16 mm increase since 0:00 on February 6)	T.P.+ 449 mm (6 mm increase since 0:00 on February 6)
	Water level of Reactor Building	T.P.+ 427 mm (11 mm increase since 0:00 on February 6)	T.P.+ 439 mm (12 mm decrease since 0:00 on February 6)	T.P.+ 497 mm (17 mm increase since 0:00 on February 6)	T.P.+ 368 mm (No change since 0:00 on February 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,648 mm (53 mm increase since 0:00 on February 6) T.P.+ 778 mm ( 14 mm increase since 0:00 on February 6) T.P.+ 2,690 mm (1 mm decrease since 0:00 on February 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.