

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 9,)**

Water Level of the accumulated water (at 0:00 on February 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 422 mm (6 mm increase since 0:00 on February 8)	T.P.+ 356 mm (26 mm decrease since 0:00 on February 8)	T.P.+ 421 mm (5 mm increase since 0:00 on February 8)
	Water level of Reactor Building	T.P.+ 435 mm (4 mm increase since 0:00 on February 8)	T.P.+ 461 mm (8 mm increase since 0:00 on February 8)	T.P.+ 508 mm (4 mm decrease since 0:00 on February 8)	T.P.+ 366 mm (1 mm decrease since 0:00 on February 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,872 mm (122 mm increase since 0:00 on February 8) T.P.+ 778 mm (No change since 0:00 on February 8) T.P.+ 2,702 mm (8 mm increase since 0:00 on February 8)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.