

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 15,)**

Water Level of the accumulated water (at 0:00 on February 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 397 mm (2 mm increase since 0:00 on February 14)	T.P.+ 361 mm (12 mm increase since 0:00 on February 14)	T.P.+ 443 mm (5 mm increase since 0:00 on February 14)
	Water level of Reactor Building	T.P.+ 432 mm (27 mm decrease since 0:00 on February 14)	T.P.+ 469 mm (10 mm increase since 0:00 on February 14)	T.P.+ 504 mm (19 mm increase since 0:00 on February 14)	T.P.+ 362 mm (No change since 0:00 on February 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,468 mm (46 mm increase since 0:00 on February 14)  T.P.+ 870 mm ( 14 mm increase since 0:00 on February 14)  T.P.+ 2,750 mm (8 mm increase since 0:00 on February 14)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.