

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 16,)**

Water Level of the accumulated water (at 0:00 on February 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 407 mm (10 mm increase since 0:00 on February 15)	T.P.+ 374 mm (13 mm increase since 0:00 on February 15)	T.P.+ 446 mm (3 mm increase since 0:00 on February 15)
	Water level of Reactor Building	T.P.+ 440 mm (8 mm increase since 0:00 on February 15)	T.P.+ 468 mm (1 mm decrease since 0:00 on February 15)	T.P.+ 518 mm (14 mm increase since 0:00 on February 15)	T.P.+ 360 mm (2 mm decrease since 0:00 on February 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,561 mm (93 mm increase since 0:00 on February 15) T.P.+ 878 mm (8 mm increase since 0:00 on February 15) T.P.+ 2,758 mm (8 mm increase since 0:00 on February 15)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.