

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on February 26,)**

Water Level of the accumulated water (at 0:00 on February 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 402 mm (14 mm increase since 0:00 on February 25)	T.P.+ 201 mm (2 mm increase since 0:00 on February 25)	T.P.+ 419 mm (3 mm increase since 0:00 on February 25)
	Water level of Reactor Building	T.P.+ 414 mm (11 mm decrease since 0:00 on February 25)	T.P.+ 452 mm (3 mm decrease since 0:00 on February 25)	T.P.+ 357 mm (5 mm increase since 0:00 on February 25)	T.P.+ 348 mm (No change since 0:00 on February 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,963 mm (71 mm decrease since 0:00 on February 25)  T.P.+ 881 mm ( No change since 0:00 on February 25)  T.P.+ 2,831 mm (8 mm increase since 0:00 on February 25)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.