

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 2,)**

Water Level of the accumulated water (at 0:00 on March 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 382 mm (8 mm decrease since 0:00 on March 1)	T.P.+ 199 mm (1 mm increase since 0:00 on March 1)	T.P.+ 441 mm (9 mm increase since 0:00 on March 1)
	Water level of Reactor Building	T.P.+ 436 mm (9 mm increase since 0:00 on March 1)	T.P.+ 455 mm (4 mm decrease since 0:00 on March 1)	T.P.+ 363 mm (6 mm increase since 0:00 on March 1)	T.P.+ 348 mm (No change since 0:00 on March 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,872 mm (71 mm increase since 0:00 on March 1) T.P.+ 882 mm (1 mm increase since 0:00 on March 1) T.P.+ 2,858 mm (6 mm increase since 0:00 on March 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.