

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 6,)**

Water Level of the accumulated water (at 0:00 on March 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 388 mm (4 mm decrease since 0:00 on March 5)	T.P.+ 376 mm (180 mm increase since 0:00 on March 5)	T.P.+ 419 mm (3 mm increase since 0:00 on March 5)
	Water level of Reactor Building	T.P.+ 447 mm (41 mm increase since 0:00 on March 5)	T.P.+ 438 mm (19 mm decrease since 0:00 on March 5)	T.P.+ 387 mm (24 mm increase since 0:00 on March 5)	T.P.+ 344 mm (3 mm decrease since 0:00 on March 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,778 mm (44 mm increase since 0:00 on March 5) T.P.+ 893 mm (4 mm increase since 0:00 on March 5) T.P.+ 2,891 mm (7 mm increase since 0:00 on March 5)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.