

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 7,)**

Water Level of the accumulated water (at 0:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 375 mm (13 mm decrease since 0:00 on March 6)	T.P.+ 359 mm (17 mm decrease since 0:00 on March 6)	T.P.+ 425 mm (6 mm increase since 0:00 on March 6)
	Water level of Reactor Building	T.P.+ 441 mm (6 mm decrease since 0:00 on March 6)	T.P.+ 445 mm (7 mm increase since 0:00 on March 6)	T.P.+ 377 mm (10 mm decrease since 0:00 on March 6)	T.P.+ 343 mm (1 mm decrease since 0:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,894 mm (116 mm increase since 0:00 on March 6) T.P.+ 898 mm (5 mm increase since 0:00 on March 6) T.P.+ 2,898 mm (7 mm increase since 0:00 on March 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.