

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 8,)**

Water Level of the accumulated water (at 0:00 on March 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 390 mm (15 mm increase since 0:00 on March 7)	T.P.+ 366 mm (7 mm increase since 0:00 on March 7)	T.P.+ 427 mm (2 mm increase since 0:00 on March 7)
	Water level of Reactor Building	T.P.+ 426 mm (15 mm decrease since 0:00 on March 7)	T.P.+ 454 mm (9 mm increase since 0:00 on March 7)	T.P.+ 378 mm (1 mm increase since 0:00 on March 7)	T.P.+ 341 mm (2 mm decrease since 0:00 on March 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,929 mm (35 mm increase since 0:00 on March 7) T.P.+ 1,067 mm (169 mm increase since 0:00 on March 7) T.P.+ 2,905 mm (7 mm increase since 0:00 on March 7)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.