

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 10,)**

Water Level of the accumulated water (at 0:00 on March 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 370 mm (17 mm decrease since 0:00 on March 9)	T.P.+ 370 mm (4 mm decrease since 0:00 on March 9)	T.P.+ 407 mm (26 mm decrease since 0:00 on March 9)
	Water level of Reactor Building	T.P.+ 606 mm (180 mm increase since 0:00 on March 9)	T.P.+ 438 mm (2 mm decrease since 0:00 on March 9)	T.P.+ 410 mm (14 mm increase since 0:00 on March 9)	T.P.+ 343 mm (No change since 0:00 on March 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,952 mm (13 mm increase since 0:00 on March 9) T.P.+ 1,379 mm (190 mm increase since 0:00 on March 9) T.P.+ 2,918 mm (7 mm increase since 0:00 on March 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.