

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 12,)**

Water Level of the accumulated water (at 0:00 on March 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 402 mm (19 mm increase since 0:00 on March 11)	T.P.+ 376 mm (10 mm increase since 0:00 on March 11)	T.P.+ 419 mm (6 mm increase since 0:00 on March 11)
	Water level of Reactor Building	T.P.+ 407 mm (8 mm decrease since 0:00 on March 11)	T.P.+ 464 mm (12 mm increase since 0:00 on March 11)	T.P.+ 394 mm (7 mm increase since 0:00 on March 11)	T.P.+ 343 mm (No change since 0:00 on March 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,960 mm (4 mm increase since 0:00 on March 11) T.P.+ 867 mm ( 367 mm decrease since 0:00 on March 11) T.P.+ 2,929 mm (5 mm increase since 0:00 on March 11)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.