

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 19,)**

Water Level of the accumulated water (at 0:00 on March 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 396 mm (4 mm increase since 0:00 on March 18)	T.P.+ 388 mm (29 mm increase since 0:00 on March 18)	T.P.+ 425 mm (5 mm increase since 0:00 on March 18)
	Water level of Reactor Building	T.P.+ 411 mm (5 mm increase since 0:00 on March 18)	T.P.+ 464 mm (5 mm increase since 0:00 on March 18)	T.P.+ 415 mm (33 mm increase since 0:00 on March 18)	T.P.+ 339 mm (No change since 0:00 on March 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,044 mm (2 mm increase since 0:00 on March 18) T.P.+ 164 mm ( 300 mm decrease since 0:00 on March 18) T.P.+ 2,959 mm (4 mm increase since 0:00 on March 18)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.