

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 30,)**

| Water Level of the accumulated water (at 0:00 on March 30) |  | Unit 1  | Unit 2   | Unit 3   | Unit 4   |
|--|--|---|--|--|--|
|  | Water level of Turbine Building  | -<br>Removal completed on March, 2017   | T.P.+ 378 mm<br>(9 mm decrease since 0:00 on March 29)   | T.P.+ 365 mm<br>(5 mm decrease since 0:00 on March 29) | T.P.+ 439 mm<br>(5 mm increase since 0:00 on March 29) |
|  | Water level of Reactor Building  | T.P.+ 427 mm<br>(9 mm increase since 0:00 on March 29)                                    | T.P.+ 462 mm<br>(33 mm increase since 0:00 on March 29)  | T.P.+ 399 mm<br>(2 mm decrease since 0:00 on March 29) | T.P.+ 339 mm<br>(No change since 0:00 on March 29)     |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building | T.P.+ 3,113 mm (3 mm increase since 0:00 on March 29)<br>T.P.+ 127 mm ( 108 mm decrease since 0:00 on March 29)<br>T.P.+ 2,993 mm (3 mm increase since 0:00 on March 29) |  |  |
| Notes  |  |   |  |  |  |

※ For quick publication of the data of water level, values are provided as reference values.