

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 31,)**

Water Level of the accumulated water (at 0:00 on March 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 383 mm (5 mm increase since 0:00 on March 30)	T.P.+ 348 mm (17 mm decrease since 0:00 on March 30)	T.P.+ 441 mm (2 mm increase since 0:00 on March 30)
	Water level of Reactor Building	T.P.+ 441 mm (14 mm increase since 0:00 on March 30)	T.P.+ 462 mm (No change since 0:00 on March 30)	T.P.+ 380 mm (19 mm decrease since 0:00 on March 30)	T.P.+ 338 mm (1 mm decrease since 0:00 on March 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,123 mm (10 mm increase since 0:00 on March 30) T.P.+ -57 mm ( 184 mm decrease since 0:00 on March 30) T.P.+ 2,995 mm (2 mm increase since 0:00 on March 30)		
Notes					

For quick publication of the data of water level, values are provided as reference values.