

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 19)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on August 19)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,280 mm (37 mm decrease since 16:00 on August 18)	O.P.+ 2,955 mm (18 mm increase since 16:00 on August 18)	—
	Water level of Turbine Building	O.P.+ 3,008 mm (7 mm increase since 16:00 on August 18)	O.P.+ 3,239 mm (31 mm decrease since 16:00 on August 18)	O.P.+ 2,860 mm (39 mm increase since 16:00 on August 18)	O.P.+ 2,803 mm (No change since 16:00 on August 18)
	Water level of Reactor Building	O.P.+ 4,118 mm (2 mm increase since 16:00 on August 18)	O.P.+ 3,319 mm (27 mm decrease since 16:00 on August 18)	O.P.+ 2,899 mm (40 mm increase since 16:00 on August 18)	O.P.+ 2,823 mm (11 mm decrease since 16:00 on August 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,413 mm (Increase from initial level:4,630 mm, 5 mm increase since 16:00 on August 18) O.P.+ 3,067 mm (Increase from initial level:3,793 mm, 106 mm decrease since 16:00 on August 18) O.P.+ 4,257 mm (Water level from floor:461 mm, 1 mm increase since 16:00 on August 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:25 on August 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:28 on August 2)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 10:02 on July 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:27 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.