

Fukushima Daiichi Nuclear Power Station: the result of measurement of sub drain

(Bq/cm³)

	Unit 1 (collected at 11:10 am, on March 30 th)	Unit 2 (collected at 11:20 am, March 30 th)	Unit 3 (collected at 11:30 am, March 30 th)	Unit 5 (collected at 10:30 am, March 30 th)	Unit 6 (collected at 10:40 am, March 30 th)
Nb-95 (About 35 days)	Below the detection limit	About 3.6×10^{-2}	Below the detection limit	Below the detection limit	Below the detection limit
Te-129 (About 70 minutes)	About 1.2×10^3	Below the detection limit	Below the detection limit	Below the detection limit	About 8.1×10^1
Te-129m (About 34 days)	About 8.7×10^0	About 1.7×10^0	Below the detection limit	Below the detection limit	About 1.3×10^0
I-131 (About 8 days)	About 4.3×10^2	About 8.0×10^1	About 2.2×10^1	About 1.6×10^0	About 2.0×10^1
I-132 (About 2 hours)	About 8.3×10^0	Below the detection limit	About 1.3×10^1	Below the detection limit	About 5.8×10^{-1}
Te-132 (About 3 days)	About 3.0×10^0	About 3.9×10^{-1}	About 5.4×10^{-1}	About 1.0×10^{-1}	About 6.0×10^{-1}
Cs-134 (About 2 years)	About 5.2×10^0	About 7.0×10^{-1}	About 1.0×10^1	About 2.5×10^{-1}	About 4.7×10^0
Cs-136 (About 13 days)	About 3.9×10^{-1}	About 6.5×10^{-2}	About 9.4×10^{-1}	About 2.7×10^{-2}	About 3.9×10^{-1}
Cs-137 (About 30 years)	About 5.9×10^0	About 6.3×10^{-1}	About 1.0×10^1	About 2.7×10^{-1}	About 4.9×10^0
La-140 (About 2 days)	About 3.3×10^{-1}	Below the detection limit	About 7.3×10^{-2}	Below the detection limit	About 4.1×10^{-2}