

Nuclide analysis of accumulated water and sub-drain water, 1F

reference

Time and Date of sample collection	15:30, Mar 28th, 2011	16:00, March 28th, 2011	10:30, March 30th, 2011	10:40, March 30th, 2011
Place of sampling	Accumulated water, Centralized Radiation Waste Treatment Facility (out of controlled area)	Accumulated water, Centralized Radiation Waste Treatment Facility (controlled area)	Sub-drain pit water, Unit 5	Sub-drain pit water, Unit 6
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)			
I-131 (approx 8 days)	6.3E+00	8.7E-01	1.6E+00	2.0E+01
Cs-134 (approx 2 years)	2.7E+00	4.4E+00	2.5E-01	4.7E+00
Cs-137 (approx 30 years)	2.8E+00	4.4E+00	2.7E-01	4.9E+00

. E - means . × 1 0 - .

I-131,Cs-134,Cs-137 are fixed figures. Data of other nuclides are under evaluation.