

Fukushima Daiichi Nuclear Power Station : Results of Nuclide Analysis of sub-drain Reference

Data summarized on April 17th)

Time and Date of sample collection	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Place of sampling	10:18, April 16th, 2011	10:15, April 16th, 2011	9:55, April 16th, 2011	9:50, April 16th, 2011	10:27, April 16th, 2011	10:30, April 16th, 2011	10:25, April 16th, 2011
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	8.4E+01	5.4E+02	4.7E+00	1.3E+01	2.0E-01	2.1E-01	1.5E-02
Cs-134 (about 2 years)	1.5E+01	5.8E+00	4.3E+00	2.7E+00	3.4E-01	3.5E-01	ND
Cs-137 (about 30 years)	1.9E+01	7.1E+00	4.5E+00	2.7E+00	3.7E-01	3.9E-01	ND

※ 〇.〇E-〇 means 〇.〇×10-〇.

※ Data of other nuclides are under evaluation.