

Fukushima Daiichi Nuclear Power Station : Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 3)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 10:30 am May 2, 2011	At 10:35 am May 2, 2011	At 10:45 am May 2, 2011	At 11:23 am May 2, 2011	At 9:40 am May 2, 2011	At 9:35 am May 2, 2011	At 10:10 am May 2, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	3.0E+01	1.9E+02	4.7E+01	1.2E-02	ND	5.9E-02	ND
Cs-134 (about 2 years)	3.4E+01	2.0E+01	2.7E+01	1.0E-01	ND	6.3E-02	ND
Cs-137 (about 30 years)	4.0E+01	2.4E+01	2.8E+01	1.1E-01	ND	7.1E-02	ND

. E - means . × 1 0 .

Data of other nuclides are under evaluation.