

| |
|-----------|
| Reference |
|-----------|

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>
 Fukushima Daiichi Nuclear Power Station the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on May 23)

| Place of Collection | Shallow Draft Quay of 1F | | Inside of north water intake canal of 1F's Unit 1-4 | | Screen of 1F's Unit 1 (outside the silt fence) | | Screen of 1F's Unit 1 (inside the silt fence) | | Screen of 1F's Unit 2 (outside the silt fence) | | Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2) |
|------------------------------------|--------------------------|----------------------|---|----------------------|--|----------------------|---|----------------------|--|----------------------|--|
| Time and date of sample collection | 2011/5/22 6:00 | | 2011/5/22 6:12 | | 2011/5/22 6:17 | | 2011/5/22 6:20 | | 2011/5/22 6:26 | | |
| Detected nuclide (half-life) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | |
| I-131 (about 8 days) | 130 | 3.3 | 1,300 | 33 | 1,300 | 33 | 1,100 | 28 | 1,300 | 33 | 40 |
| Cs-134 (about 2 years) | 640 | 11 | 5,100 | 85 | 5,000 | 83 | 4,700 | 78 | 5,200 | 87 | 60 |
| Cs-137 (about 30 years) | 700 | 7.8 | 5,400 | 60 | 5,200 | 58 | 4,900 | 54 | 5,500 | 61 | 90 |

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

| |
|-----------|
| Reference |
|-----------|

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>
 Fukushima Daiichi Nuclear Power Station the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on May 23)

| Place of Collection | Screen of 1F's Unit 2 (inside the silt fence) | | Screen of 1F's Unit 3 (outside the silt fence) | | Screen of 1F's Unit 3 (inside the silt fence) | | Screen of 1F's Unit 4 (outside the silt fence) | | Screen of 1F's Unit 4 (inside the silt fence) | | Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2) |
|---------------------------------------|--|----------------------------|---|----------------------------|--|----------------------------|---|----------------------------|--|----------------------------|---|
| Time and date of sample collection | 2011/5/22 6:30 | | 2011/5/22 6:34 | | 2011/5/22 6:38 | | 2011/5/22 6:35 | | 2011/5/22 6:40 | | |
| Detected nuclide (half-life) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | |
| I-131 (about 8 days) | 4,600 | 120 | 1,300 | 33 | 2,100 | 53 | 620 | 16 | 420 | 11 | 40 |
| Cs-134 (about 2 years) | 6,400 | 110 | 5,000 | 83 | 36,000 | 600 | 2,600 | 43 | 1,800 | 30 | 60 |
| Cs-137 (about 30 years) | 6,800 | 76 | 5,200 | 58 | 38,000 | 420 | 2,700 | 30 | 1,900 | 21 | 90 |

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/L" converted from the value originally in "Bq/cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>
 Fukushima Daiichi Nuclear Power Station the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on May 23)

| Place of Collection | Inside the south of 1F's Unit 1-4 Water Intake Canal | | | | | | | | | | Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2) |
|------------------------------------|--|----------------------|--------------------------|----------------------|--------------------------|----------------------|--------------------------|----------------------|--------------------------|----------------------|--|
| Time and date of sample collection | 2011/5/22 6:46 | | | | | | | | | | |
| Detected nuclide (half-life) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | Density of sample (Bq/L) | Scaling factor (/) | |
| I-131 (about 8 days) | 130 | 3.3 | / | / | / | / | / | / | / | / | 40 |
| Cs-134 (about 2 years) | 640 | 11 | / | / | / | / | / | / | / | / | 60 |
| Cs-137 (about 30 years) | 680 | 7.6 | / | / | / | / | / | / | / | / | 90 |

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".
 Data of other nuclides are under evaluation.
 In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1